Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM535

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: JAMES DOLPHIN	Phone #
Mailing Address: W4929 COUNTY RD F	
City: WALDO	State: WI — Zip Code: 53093
County: Sheboygan	Co. Permit #: — Notification #: 10209108201 — Completed: 04-08-2026
Well Constructor (Business Name): HYINK WELL DRILLING INC	Lic. #: 479 — Facility ID # (Public Wells):
Address: N6250 ALPINE RD, SHEBOYGAN FALLS WI 53085	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.4

1. Well Location

Town of HOLLAND	Fire # (if avail.): W2227
Street Address or Road Name and Number: HOFTIEZER RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 43.60462 °N -87.80606 °W	Method Code: GPS008
SW SE or Govt Lot #:	Section: 12 — Township: 13 N — Range: 22 E

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	142

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
F	F-FILL	Surface	2
C	C-CLAY	2	51
S	S-SAND	51	60
G	G-GRAVEL/STONES	60	68
L	L-LIMESTONE/DOLOMITE	68	142

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625X.280A53B EWBE MV 20' BLACK STEEL	Surface	68
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface		1 S

9. Static Water Level
17 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 12 GP M for 2 Hrs.
Pumping Method ? Airlift

11. Well Is
21 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RJH	7432	04-09-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TJH	3854	04-09-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-09-2026 Updated On: 05-20-2026 Review Status: APPROVED