

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM535		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner JAMES DOLPHIN					Phone #			1. Well Location				Fire # (if avail.)									
Mailing Address W4929 COUNTY RD F								Town of HOLLAND				W2227									
City WALDO					State WI		Zip Code 53093		Street Address or Road Name and Number				HOFTIEZER RD								
County Sheboygan		Co. Permit #		Notification # 10209108201		Completed 04-08-2026		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) HYINK WELL DRILLING INC					Lic. # 479		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code								
Address N6250 ALPINE RD SHEBOYGAN FALLS WI 53085					Well Plan Approval #		Approval Date (mm-dd-yyyy)		SW SE		Section 12		Township 13 N		Range 22 E						
									or Govt Lot #												
Hicap Permanent Well #			Common Well #			Specific Capacity 0.4			2. Well Type New Well				of previous unique well #		constructed in						
									Reason for replaced or reconstructed well ?												
3. Well serves 1 # of HOME					Hicap Well ? No			Construction Type Drilled													
Private, potable					Hicap Property ? No																
Heat Exchange ___ # of drillholes					Hicap Potable ? No																
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
6		Surface		142		No Rotary - Mud Circulation No No Rotary - Air Yes No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)						F F-FILL		Surface		2					
												C C-CLAY		2		51					
												S S-SAND		51		60					
												G G-GRAVEL/STONES		60		68					
												L L-LIMESTONE/DOLOMITE		68		142					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		17 ft. below ground surface				21 in. above grade							
6		6.625X.280A53B EWBE MV 20' BLACK STEEL				Surface		68		10. Pump Test				Developed ? Yes							
										Pumping level 50 ft. below surface				Disinfected ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 12 GP M for 2 Hrs.				Capped ? Yes							
										Pumping Method ? Airlift											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?				No			
Method MOUNDED														Filled & Sealed Well(s) as needed?				No			
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
#8 BENTONITE				Surface				1 S													
13. Constructor / Supervisory Driller														Lic #		Date Signed					
RJH														7432		04-09-2026					
Drill Rig Operator														Lic or Reg #		Date Signed					
TJH														3854		04-09-2026					

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-09-2026

Updated On: 05-20-2026

Review Status: APPROVED