Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM536

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: TURTLE CREEK HOMES	Phone #: (262)880-1884
Mailing Address: N4519 VAN TREEK TRAIL	
City: SHEBOYGAN FALLS	State: WI	Zip Code: 53085
County: Sheboygan	Co. Permit #:	Notification #: 10204897501	Completed: 03-31-2026
Well Constructor (Business Name): HYINK WELL DRILLING INC	Lic. #: 479	Facility ID # (Public Wells):
Address: N6250 ALPINE RD SHEBOYGAN FALLS WI 53085	Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4

1. Well Location

Town of LIMA				Fire # (if avail.): N4519
Street Address or Road Name and Number: VAN TREEK TRAIL				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 43.70252 °N -87.81068 °W				Method Code: GPS008
NE	NW	Section: 12	Township: 14 N	Range: 22 E
or Govt Lot #				

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	103

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	S-SAND	Surface	20
C	C-CLAY	20	83
L	L-LIMESTONE/DOLOMITE	83	103

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	6.625X.280A53B EWBE MV 20' BLACK STEEL	Surface	83
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
#8 BENTONITE	Surface		2 S

9. Static Water Level
43 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 12 GP M for 2 Hrs.
Pumping Method ? Airlift

11. Well Is
26 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
RJH	7432	04-09-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TJH	3854	04-09-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary	=	22	Sewer - Building Sanitary	=	90
			Septic or Holding, or POWTS Tank	=	145

Comment:

Created On: 04-09-2026 Updated On: 05-04-2026 Review Status: APPROVED