

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM536		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner TURTLE CREEK HOMES				Phone # (262)880-1884		1. Well Location				Fire # (if avail.) N4519	
Mailing Address N4519 VAN TREEK TRAIL						Town of LIMA					
City SHEBOYGAN FALLS				State WI		Zip Code 53085				Street Address or Road Name and Number VAN TREEK TRAIL	
County Sheboygan		Co. Permit #		Notification # 10204897501		Completed 03-31-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) HYINK WELL DRILLING INC				Lic. # 479		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.70252 °N -87.81068 °W		Method Code GPS008	
Address N6250 ALPINE RD SHEBOYGAN FALLS WI 53085				Well Plan Approval #		NE NW Section Township Range or Govt Lot # 12 14 N 22 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.4		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?		Construction Type Drilled			
Private, potable				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
6		Surface		103		No Rotary - Mud Circulation No No Rotary - Air Yes No Rotary - Air & Foam No Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
S		S-SAND				Surface		20			
C		C-CLAY				20		83			
L		L-LIMESTONE/DOLOMITE				83		103			
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6		6.625X.280A53B EWBE MV 20' BLACK STEEL				Surface		83			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
#8 BENTONITE				Surface				2 S			
9. Static Water Level											
43 ft. below ground surface											
10. Pump Test											
Pumping level 70 ft. below surface											
Pumping at 12 GP M for 2 Hrs.											
Pumping Method ? Airlift											
11. Well Is											
26 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? No											
13. Constructor / Supervisory Driller											
Lic #				Date Signed							
RJH				7432				04-09-2026			
Drill Rig Operator											
Lic or Reg #				Date Signed							
TJH				3854				04-09-2026			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary	=	22	Sewer - Building Sanitary	=	90
			Septic or Holding, or POWTS Tank	=	145

Comment:

Created On: 04-09-2026

Updated On: 05-04-2026

Review Status: APPROVED