Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM548

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SUMTER TOM			Phone #: (715)572-8550
Mailing Address: 513 CZECH AVE			
City: FRIENDSHIP	State: WI	Zip Code: 53934	
County: Adams	Co. Permit #:	Notification #: 10214298401	Completed: 04-08-2026

Well Constructor (Business Name): REICHHOFF, RODNEY J	Lic. #: 7202	Facility ID # (Public Wells):	
Address: W8740 EVERGREEN DR OXFORD WI 53952		Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.6	

1. Well Location

Town of RICHFIELD				Fire # (if avail.): 513
Street Address or Road Name and Number: CZECH AVE				
Subdivision Name:			Lot #: 100	Block #:
Latitude / Longitude in Decimal Degree (DD): 43.9959 °N -89.6817 °W				Method Code: GPS008
NE NE or Govt Lot #	Section: 32	Township: 18 N	Range: 7 E	

2. Well Type Replacement
of previous unique well # constructed in
Reason for replaced or reconstructed well ?: HOLE IN PIPE
Construction Type: Jetted

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
2	Surface	39
1.25	39	43

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 1.25in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	M	S		M-MEDIUM S-SAND	Surface	39
		Y		Y-SAND & GRAVEL	39	43

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
2	WHEATLAND ERW ASTM A 53 3.75# COUPLED	Surface	39
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
1.25	80 GA STAINLESS STEEL 4' POINT	39	43

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	25	1

9. Static Water Level
14 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RR	7202	04-21-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		80	POWTS dispersal component (soil absorption unit or mound)		82

Comment:

Created On: 04-10-2026 Updated On: 05-13-2026 Review Status: APPROVED