

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM548		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner SUMTER TOM				Phone # (715)572-8550		1. Well Location				Fire # (if avail.)	
Mailing Address 513 CZECH AVE						Town of RICHFIELD				513	
City FRIENDSHIP				State WI Zip Code 53934		Street Address or Road Name and Number CZECH AVE					
County Adams		Co. Permit #		Notification # 10214298401		Completed 04-08-2026		Subdivision Name		Lot # 100 Block #	
Well Constructor (Business Name) REICHHOFF, RODNEY J				Lic. # 7202		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 43.9959 °N -89.6817 °W		Method Code GPS008	
Address W8740 EVERGREEN DR OXFORD WI 53952				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 32 18 N 7 E		2. Well Type Replacement			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6		Reason for replaced or reconstructed well ? HOLE IN PIPE			
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable		Hicap Property ? No		Construction Type Jetted	
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
2		Surface		39		No Rotary - Mud Circulation			No		
1.25		39		43		No Rotary - Air			No		
						No Rotary - Air & Foam			No		
						No Drill-Through Casing Hammer					
						No Reverse Rotary					
						Yes Cable-tool Bit 1.25in. dia...			No		
						No Dual Rotary			No		
						No Temp. Outer Casing ___ in. dia					
						No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
M S		M-MEDIUM S-SAND		Surface		39					
Y		Y-SAND & GRAVEL		39		43					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification		From (ft.)		To (ft.)					
2		WHEATLAND ERW ASTM A 53 3.75# COUPLED		Surface		39					
Dia. (in.)		Screen type, material & slot size		From (ft.)		To (ft.)					
1.25		80 GA STAINLESS STEEL 4' POINT		39		43					
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement					
GRANULAR BENTONITE		Surface		25		1					
9. Static Water Level											
14 ft. below ground surface											
10. Pump Test											
Pumping level 30 ft. below surface											
Pumping at 10 GP M for 2 Hrs.											
Pumping Method ? Test Pump											
11. Well Is											
18 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? Yes											
Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller											
Lic #		Date Signed									
RR		7202		04-21-2026							
Drill Rig Operator		Lic or Reg #		Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		80	POWTS dispersal component (soil absorption unit or mound)		82

Comment:

Created On: 04-10-2026

Updated On: 05-13-2026

Review Status: APPROVED