

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM551		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner LAKESIDE LUXURY HOMES				Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 10033 NORTH PORT WASHINGTON RD SUITE 300						City of MEQUON									
City MEQUON				State WI		Zip Code 53092									
County Ozaukee		Co. Permit #		Notification # 10136993901		Completed 04-09-2026		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) SWEENEY, KENNETH R				Lic. # 583		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2431 °N -87.9134 °W				Method Code GPS008	
Address KEN SWEENEY WELL DRILLING & PUMPS 11221 W ST MARTINS RD FRANKLIN WI 53132-2331				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 17 9 N 22 E				2. Well Type New Well					
Hicap Permanent Well #				Common Well #		Specific Capacity 1.1				Reason for replaced or reconstructed well ?					
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No					
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		202		No Rotary - Mud Circulation				No					
						No Rotary - Air				Yes					
						No Rotary - Air & Foam				No					
						Yes Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
T C		T-TAN/BROWN C-CLAY				Surface		13							
U C		U-BLUE C-CLAY				13		178							
L		L-LIMESTONE/DOLOMITE				178		202							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		18.97#/FT ASTM A53B WHEATLAND WELDED				Surface		178							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface											
9. Static Water Level															
122 ft. below ground surface															
10. Pump Test															
Pumping level 160 ft. below surface															
Pumping at 40 GP M for 2 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
KS				583		04-10-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									
MW				7359		04-10-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		160	Sewer - Building Sanitary		9

Comment:

Created On: 04-10-2026

Updated On: 05-04-2026

Review Status: APPROVED