Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM551

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: LAKESIDE LUXURY HOMES	Phone #
Mailing Address: 10033 NORTH PORT WASHINGTON RD SUITE 300	
City: MEQUON	State: WI — Zip Code: 53092
County: Ozaukee	Co. Permit #: — Notification #: 10136993901 — Completed: 04-09-2026
Well Constructor (Business Name): SWEENEY, KENNETH R	Lic. #: 583 — Facility ID # (Public Wells):
Address: KEN SWEENEY WELL DRILLING & PUMPS 11221 W ST MARTINS RD FRANKLIN WI 53132-2331	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.1

1. Well Location

City of MEQUON — Fire # (if avail.):

Street Address or Road Name and Number: 12360 N LAKESHORE DR

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 43.2431 °N -87.9134 °W — Method Code: GPS008

NW SE or Govt Lot #: — Section: 17 — Township: 9 N — Range: 22 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	202

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T		C		T-TAN/BROWN C-CLAY	Surface	13
U		C		U-BLUE C-CLAY	13	178
		L		L-LIMESTONE/DOLOMITE	178	202

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18.97#/FT ASTM A53B WHEATLAND WELDED	Surface	178
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

122 ft. below ground surface

10. Pump Test

Pumping level 160 ft. below surface

Pumping at 40 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KS	583	04-10-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
MW	7359	04-10-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary		160	Sewer - Building Sanitary		9

Comment:

Created On: 04-10-2026 Updated On: 05-04-2026 Review Status: APPROVED