Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACM555

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ANDY C YODER	Phone #
Mailing Address: 24094 LAKE RD	
City: CASHTON	State: WI — Zip Code: 54619
County: Monroe	Co. Permit #: — Notification #: 10205903201 — Completed: 04-06-2026
Well Constructor (Business Name): SCHAITEL, JAKE J	Lic. #: 3822 — Facility ID # (Public Wells):
Address: TRI COUNTY WELL DRILLING 8301 IDOL AVE, SPARTA WI 54656-5603	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.3

1. Well Location

Town of LITTLE FALLS	Fire # (if avail.): 5967
Street Address or Road Name and Number: HWY 71	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.0589 °N -90.8731 °W	Method Code: SCR002
SE SE or Govt Lot #: — Section: 5 — Township: 18 N — Range: 4 W	

2. Well Type: New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves: 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	80
6	80	140

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
Yes	Rotary - Air & Foam	Yes
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
R	V	X		R-RED V-NON-CAVING X-SAND & CLAY	Surface	3
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	3	71
T	S	N		T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE	71	78
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	78	140

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PE BLACK STEEL ASTMA 53 A 19.85 280 WALL WELD WHEATLAND USA PIPE	Surface	80
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
89 ft. below ground surface

10. Pump Test
Pumping level 120 ft. below surface
Pumping at 10 GP M for 3 Hrs.
Pumping Method ? Airlift

11. Well Is
26 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	80	20 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JS	3822	04-10-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: NO POTENTIAL CONTAMINATION SOURCES AT TIME OF DRILLING

Created On: 04-10-2026 Updated On: 05-04-2026 Review Status: APPROVED