

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM555		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner ANDY C YODER					Phone #		1. Well Location				Fire # (if avail.)						
Mailing Address 24094 LAKE RD							Town of LITTLE FALLS				5967						
City CASHTON					State WI		Zip Code 54619				Street Address or Road Name and Number HWY 71						
County Monroe		Co. Permit #		Notification # 10205903201		Completed 04-06-2026		Subdivision Name			Lot # Block #						
Well Constructor (Business Name) SCHAITEI, JAKE J				Lic. # 3822		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.0589 °N -90.8731 °W			Method Code SCR002						
Address TRI COUNTY WELL DRILLING 8301 IDOL AVE SPARTA WI 54656-5603				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 5 18 N 4 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled									
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #			Common Well #		Specific Capacity 0.3												
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes					Hicap Well ? No Hicap Property ? No Hicap Potable ? No												
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
10		Surface		80		No Rotary - Mud Circulation		No		R V X		R-RED V-NON-CAVING X-SAND & CLAY		Surface		3	
6		80		140		No Rotary - Air		No		T H N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE		3		71	
						Yes Rotary - Air & Foam		Yes		T S N		T-TAN/BROWN S-SOFT/LOOSE N-SANDSTONE		71		78	
						No Drill-Through Casing Hammer Reverse Rotary				T H N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE		78		140	
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		89 ft. below ground surface		26 in. above grade					
6		NEW PE BLACK STEEL ASTM A 53 A 19.85 280 WALL WELD WHEATLAND USA PIPE				Surface		80		10. Pump Test		Developed ? Yes Disinfected ? Yes Capped ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 120 ft. below surface							
										Pumping at 10 GP M for 3 Hrs.							
										Pumping Method ? Airlift							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method TREMIE PIPE - PUMPED																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No							
NEAT CEMENT GROUT				Surface		80		20 S									
13. Constructor / Supervisory Driller												Lic #		Date Signed			
JS												3822		04-10-2026			
Drill Rig Operator												Lic or Reg #		Date Signed			

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment: NO POTENTIAL CONTAMINATION SOURCES AT TIME OF DRILLING

Created On: 04-10-2026

Updated On: 05-04-2026

Review Status: APPROVED