

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM560		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner HICKMAN, LOGAN					Phone # (970)302-3535		1. Well Location				Fire # (if avail.)			
Mailing Address 184091 ST HWY 153							Village of ELDERON							
City ELAND					State WI		Zip Code 54427		Street Address or Road Name and Number 184091 ST HWY 153					
County Marathon		Co. Permit #		Notification # 10164933601		Completed 03-09-2026		Subdivision Name			Lot #		Block #	
Well Constructor (Business Name) DREWS WELL DRILLING INC				Lic. # 5900		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.7836 °N -89.249 °W				Method Code GPS008		
Address 170001 RINGLE AVE RINGLE WI 54471				Well Plan Approval #		NE NE		Section 35		Township 27 N		Range 10 E		
				Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #			Common Well #		Specific Capacity 0		2. Well Type Replacement							
						of previous unique well # constructed in								
Reason for replaced or reconstructed well ?						BASEMENT LOCATION / REAL ESTATE								
3. Well serves # of HOME						Hicap Well ? No								
Private, potable						Hicap Property ? No								
Heat Exchange ___ # of drillholes						Hicap Potable ? No								
						Construction Type Drilled								
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock					
6		Surface		40		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>No</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>Yes</u> Cable-tool Bit 6in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)								
8. Geology														
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)					
Q Y			Q-CAVING Y-SAND & GRAVEL			Surface			40					
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		WHEATLAND A53B 18.97LBS/FT WELDED				Surface		37						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
5		STAINLESS STEEL 12 SLOT W/KPAK				37		40						
7. Grout or Other Sealing Material														
Method MOUNDED														
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						
GRANULAR BENTONITE				Surface				0.5 S						
9. Static Water Level														
12 ft. below ground surface														
10. Pump Test														
Pumping level 20 ft. below surface														
Pumping at 15 GP M for 1 Hrs.														
Pumping Method ? Test Pump														
11. Well Is														
24 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ? Yes														
Filled & Sealed Well(s) as needed? Yes														
WHEN THE NEW WELL IS CONNECTED														
13. Constructor / Supervisory Driller						Lic #		Date Signed						
EJD						5686		04-12-2026						
Drill Rig Operator						Lic or Reg #		Date Signed						
MPK						7436		04-12-2026						

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		90	POWTS dispersal component (soil absorption unit or mound)		110

Comment:

Created On: 04-12-2026

Updated On: 05-27-2026

Review Status: APPROVED