

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM562		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner OTTUM, TANYA				Phone # (715)474-6798		1. Well Location				Fire # (if avail.)	
Mailing Address W2690 SOUTH STREET						Village of INGRAM				W2690	
City INGRAM				State WI		Zip Code 54535				Street Address or Road Name and Number SOUTH STREET	
County Rusk		Co. Permit #		Notification # 10122616801		Completed 04-13-2026		Subdivision Name		Lot # Block #	
Well Constructor (Business Name) KOMAREK, RONALD A SR				Lic. # 610		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.504 °N -90.8114 °W		Method Code GPS008	
Address N1690 STATE HIGHWAY 13 OGEMA WI 54459				Well Plan Approval #		SW NE Section Township Range or Govt Lot # 24 35 N 4 W		2. Well Type Reconstruction			
Hicap Permanent Well #				Common Well #		Specific Capacity 3		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?		POINT WELL DRY			
Private, potable				Hicap Property ? No		Construction Type Drilled					
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock		
6		Surface		60		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)					
8. Geology											
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)		
H G			H-HARD/FIRM G-GRAVEL/STONES			Surface			14		
C			C-CLAY			14			44		
K			K-COBBLER/BOULDERS			44			47		
Y U			Y-SAND & GRAVEL U-MUDDY OR MURKY			47			59		
E G			E-CLEAN G-GRAVEL/STONES			59			60		
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)			
6.6		.280 ASTM A53B, 18.97# WEDT JT, WHEATLAND				Surface		60			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)			
7. Grout or Other Sealing Material											
Method MOUNDED											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement			
GRANULAR BENTONITE				Surface							
9. Static Water Level											
19 ft. below ground surface											
10. Pump Test											
Pumping level 25 ft. below surface											
Pumping at 18 GP M for 10 Hrs.											
Pumping Method ? Test Pump											
11. Well Is											
24 in. above grade											
Developed ? Yes											
Disinfected ? Yes											
Capped ? Yes											
12. Notified Owner of need to fill & seal ? No											
Filled & Sealed Well(s) as needed? Yes											
13. Constructor / Supervisory Driller											
Lic #				Date Signed							
RJK				6961				05-06-2026			
Drill Rig Operator				Lic or Reg #				Date Signed			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-13-2026

Updated On: 05-27-2026

Review Status: APPROVED