Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM562

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OTTUM, TANYA	Phone #: (715)474-6798
Mailing Address: W2690 SOUTH STREET	
City: INGRAM	State: WI — Zip Code: 54535
County: Rusk	Co. Permit #:
Notification #: 10122616801	Completed: 04-13-2026
Well Constructor (Business Name): KOMAREK, RONALD A SR	Lic. #: 610
Facility ID # (Public Wells):	
Address: N1690 STATE HIGHWAY 13 OGEMA WI 54459	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 3	

1. Well Location

Village of INGRAM	Fire # (if avail.): W2690
Street Address or Road Name and Number: SOUTH STREET	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 45.504 °N -90.8114 °W	Method Code: GPS008
SW NE or Govt Lot #:	Section: 24 — Township: 35 N — Range: 4 W

2. Well Type Reconstruction

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: POINT WELL DRY

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	H	G		H-HARD/FIRM G-GRAVEL/STONES	Surface	14
		C		C-CLAY	14	44
		K		K-COBBLES/BOULDERS	44	47
		Y	U	Y-SAND & GRAVEL U-MUDDY OR MURKY	47	59
	E	G		E-CLEAN G-GRAVEL/STONES	59	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.6	.280 ASTM A53B, 18.97# WEDT JT, WHEATLAND	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

19 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 18 GP M for 10 Hrs.

Pumping Method ? Test Pump

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
RJK	6961	05-06-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 04-13-2026 Updated On: 05-27-2026 Review Status: APPROVED