

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM570		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner SCHULTZ, DAN					Phone #		1. Well Location				Fire # (if avail.)		
Mailing Address 200 SHEFFIELD DR.							Town of DELL PRAIRIE				3857		
City RACINE					State WI		Zip Code 53402				Street Address or Road Name and Number		
9TH AVE.													
County Adams		Co. Permit # 1		Notification # 10197836401		Completed 04-13-2026		Subdivision Name				Lot #	
												Block #	
Well Constructor (Business Name)				Lic. # 6143		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)			
WALKER, BRUCE A										43.69123 °N -89.75858 °W			
										Method Code			
										SCR002			
Address WISCONSIN WELL & WATER SYSTEMS LLC 673 FERN AVE GRAND MARSH WI 53936				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 15 14 N 6 E							
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #				Common Well #		Specific Capacity				Reason for replaced or reconstructed well ?			
						0							
3. Well serves 1 # of HOME						Hicap Well ? No							
Private, potable						Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ? No							
						Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole						Lower Open Bedrock				
10.25 Surface 154													
6 154 201			Yes Rotary - Mud Circulation Yes										
			No Rotary - Air No										
			No Rotary - Air & Foam No										
			No Drill-Through Casing Hammer										
			No Reverse Rotary										
			No Cable-tool Bit ___ in. dia... No										
			No Dual Rotary No										
			No Temp. Outer Casing ___ in. dia										
			No Removed? ___ depth ft. (If NO explain on back side)										
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)				
M S			M-MEDIUM S-SAND						Surface 60				
H X			H-HARD/FIRM X-SAND & CLAY						60 68				
A S			A-COARSE S-SAND						68 86				
X M			X-SAND & CLAY M-SILTY						86 140				
N S			N-FINE S-SAND						140 151				
H N			H-HARD/FIRM N-SANDSTONE						151 201				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		CRESTLINE PVC 1120, SDR 21 200 PSI, ASTM 2265 F480 WITH SHALE TRAP				Surface		154					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
QUIK GROUT				Surface		150		15 S					
9. Static Water Level													
75 ft. below ground surface													
10. Pump Test													
Pumping level 95 ft. below surface													
Pumping at 15 GP M for 2.5 Hrs.													
Pumping Method ? Test Pump													
11. Well Is													
24 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ? No													
Filled & Sealed Well(s) as needed? No													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
BW 6143				04-14-2026									
Drill Rig Operator				Lic or Reg #				Date Signed					
DC 9106				04-13-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Sewer - Building Sanitary	>	25
			Septic or Holding, or POWTS Tank	>	100

Comment:

WATER SAMPLE TO BE TAKEN AT TIME OF PUMP HOOK UP

ENCOUNTERED INTERMITTENT FRACTURES THROUGHOUT THE SANDSTONE FORMATION. PLACED 1 BAG OF 3/8" CHIPS AT BOTTOM OF ANNUALR SPACE TO SEAL ANY FRACTURES, ALLOWING NEAT GROUT TO BE PLACED TO SURFACE.

Variance ID	Variance or Exception Type	Date	Reason
78625	Landfill Variance	12/05/2025	WITHIN 1200 FEET OF LANDFILL

Created On: 04-13-2026

Updated On: 05-28-2026

Review Status: APPROVED