Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM576

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STONER,BETH	Phone #: (715)874-6789
Mailing Address: 105 WEST FILMORE AVENUE	
City: EAU CLAIRE	State: WI — Zip Code: 54701

County	Co. Permit #	Notification #	Completed
Dunn	2604081	10216059003	04-13-2026

Well Constructor (Business Name): J & K PUMP & WELL SERVICE	Lic #: 8364
Address: 20458 80TH AVE CADOTT WI 54727	

Facility ID # (Public Wells):
Well Plan Approval #:
Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #

Specific Capacity: 0.5

1. Well Location

Town of ROCK CREEK

Fire # (if avail.): M1396

Street Address or Road Name and Number: 934TH STREET

Subdivision Name	Lot #	Block #
	1	

Latitude / Longitude in Decimal Degree (DD): 44.7302 °N -91.6881 °W
Method Code: GPS008

SW	SW	Section	Township	Range
or Govt Lot #		14	26 N	11 W

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	140.5

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	S	S		T-TAN/BROWN S-SOFT/LOOSE S-SAND	Surface	40
T	V	X		T-TAN/BROWN V-NON-CAVING X-SAND & CLAY	40	128
G	S	S		G-GRAY S-SOFT/LOOSE S-SAND	128	140.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL THREADED AND CUPPLED 20 LBS PER FT ASTM A 53 B 1800 PSI WHEATLAND PIPE	Surface	137
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON STAINLESS STEEL 10 SLOT	136.5	140.5

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level
80 ft. below ground surface

10. Pump Test
Pumping level 101 ft. below surface
Pumping at 10 GP M for 3 Hrs.
Pumping Method ? Test Pump

11. Well Is
25 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JK	6336	04-30-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JK	6336	04-30-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	75	Sewer - Building Sanitary	=	39
Building Drain - Sanitary	=	25	Septic or Holding, or POWTS Tank	=	35

Comment:

Created On: 04-13-2026 Updated On: 05-29-2026 Review Status: APPROVED