

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM578		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A		
Property Owner DURHAM, KENNETH					Phone #		1. Well Location Fire # (if avail.) 3592					
Mailing Address 1187 64TH ST												
City HUDSON			State WI		Zip Code 54016		Town of CLAM FALLS					
Street Address or Road Name and Number							115TH ST					
County Polk		Co. Permit #		Notification # 10223085101		Completed 04-13-2026		Subdivision Name			Lot # Block #	
Well Constructor (Business Name) CHELL WELL DRILLING				Lic. # 22		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.72484 °N -92.39606 °W			Method Code SCR002	
Address 1471 345TH AVE FREDERIC WI 54837				Well Plan Approval #		NW NE Section Township Range		or Govt Lot # 6 37 N 16 W				
				Approval Date (mm-dd-yyyy)		2. Well Type New Well		of previous unique well # constructed in				
Hicap Permanent Well #		Common Well #		Specific Capacity 0		Reason for replaced or reconstructed well ?						
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No		Construction Type Drilled						
4. Potential Contamination Sources - ON REVERSE SIDE												
5. Drillhole Dimensions and Construction Method												
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		
6		Surface		97		No Rotary - Mud Circulation Yes Rotary - Air No Rotary - Air & Foam Yes Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No Dual Rotary No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				S S-SAND Surface 18 Z Z-CLAY & GRAVEL 18 55 Y M Y-SAND & GRAVEL M-SILTY 55 90 Y Y-SAND & GRAVEL 90 97		
6. Casing, Liner, Screen												
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		9. Static Water Level 47 ft. below ground surface		
6		STEEL PE 18.97#/FT ASTM A53 WHEATLAND WELD				Surface		93		11. Well Is 18 in. above grade		
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes Disinfected ? Yes Capped ? Yes		
4		TELESCOPED STAINLESS STEEL 15 SLOT				93		97		10. Pump Test Pumping level 71 ft. below surface Pumping at 35 GP M for 1 Hrs. Pumping Method ? Airlift		
7. Grout or Other Sealing Material Method MOUNDED												
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No				
GRANULAR BENTONITE		Surface						Filled & Sealed Well(s) as needed? No				
13. Constructor / Supervisory Driller												
DJC		6846		04-13-2026		Lic #		Date Signed				
Drill Rig Operator		Lic or Reg #		Date Signed								

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-13-2026

Updated On: 05-06-2026

Review Status: APPROVED