Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM578

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DURHAM, KENNETH			Phone #
Mailing Address: 1187 64TH ST			
City: HUDSON	State: WI	Zip Code: 54016	
County: Polk	Co. Permit #:	Notification #: 10223085101	Completed: 04-13-2026

Well Constructor (Business Name): CHELL WELL DRILLING	Lic. #: 22	Facility ID # (Public Wells):	
Address: 1471 345TH AVE FREDERIC WI 54837		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.5	

1. Well Location

Town of CLAM FALLS				Fire # (if avail.): 3592
Street Address or Road Name and Number: 115TH ST				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 45.72484 °N -92.39606 °W				Method Code: SCR002
NW NE or Govt Lot #:	Section: 6	Township: 37 N	Range: 16 W	

2. Well Type New Well
of previous unique well #: constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	97

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	18
		Z		Z-CLAY & GRAVEL	18	55
		Y	M	Y-SAND & GRAVEL M-SILTY	55	90
		Y		Y-SAND & GRAVEL	90	97

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL PE 18.97#/FT ASTM A53 WHEATLAND WELD	Surface	93
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	TELESCOPED STAINLESS STEEL 15 SLOT	93	97

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		

9. Static Water Level
47 ft. below ground surface

10. Pump Test
Pumping level 71 ft. below surface
Pumping at 35 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DJC	6846	04-13-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-13-2026 Updated On: 10-15-2026 Review Status: APPROVED