Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM595

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SANDBERG LYLE	Phone #: (715)220-6706
Mailing Address: S9810 SANDBERG RD	
City: EAU CLAIRE	State: WI Zip Code: 54701

County	Co. Permit #	Notification #	Completed
Eau Claire	35109	10224570001	04-15-2026

Well Constructor (Business Name): OIUM, KELLY WELL DRILLING INC	Lic. #: 8217
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: N50021 MISSELL ROAD STRUM WI 54770	Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #
Specific Capacity: 6	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of BRUNSWICK

Fire # (if avail.): S9810

Street Address or Road Name and Number: SANDBERG RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.69054 °N -91.57801 °W
Method Code: GPS008

NW SE or Govt Lot #	Section	Township	Range
	34	26 N	10 W

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
LACK OF WATER - MUDDY WATER AFTER STORMS

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	55
6	55	180

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 10in. dia...	No
No	Dual Rotary	Yes
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		I-SOIL-ORGANIC	Surface	3
E	H	N	H	E-GREEN H-HARD/FIRM N-SANDSTONE H-SHALEY	3	26
T	H	N	H	T-TAN/BROWN H-HARD/FIRM N-SANDSTONE H-SHALEY	26	53
E	H	N	H	E-GREEN H-HARD/FIRM N-SANDSTONE H-SHALEY	53	98
Y	H	N		Y-YELLOW H-HARD/FIRM N-SANDSTONE	98	123
T	H	N		T-TAN/BROWN H-HARD/FIRM N-SANDSTONE	123	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	VICTOR PIPE & STEEL 6.620XA53B.280 EWTC	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
150 ft. below ground surface

10. Pump Test
Pumping level 152 ft. below surface
Pumping at 12 GP M for 2 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	60	18 S

12. Notified Owner of need to fill & seal ? No
FILL & SEALING BY ANOTHER CONTRACTOR

Filled & Sealed Well(s) as needed? No
FILL & SEALING BY ANOTHER CONTRACTOR

13. Constructor / Supervisory Driller	Lic #	Date Signed
KO	6244	05-07-2026
Drill Rig Operator	Lic or Reg #	Date Signed
JG	8980	05-07-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		108	POWTS dispersal component (soil absorption unit or mound)		205

Comment:

Created On: 04-14-2026 Updated On: 06-01-2026 Review Status: APPROVED