

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM605		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner SHODEEN					Phone #			1. Well Location				Fire # (if avail.)					
Mailing Address 77 N 1ST								City of DELAVAN									
City GENEVA					State IL		Zip Code 60134		Street Address or Road Name and Number				3987 WHITING				
County Walworth		Co. Permit #		Notification # 10216999301		Completed 04-09-2026		Subdivision Name			Lot # 42		Block #				
Well Constructor (Business Name) GEHRING, LANCE M				Lic. # 6994		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.6346 °N -88.5873 °W				Method Code GPS008					
Address LANCE GEHRING WELL DRILLING 8820 KAROW RD TWIN LAKES WI 53181				Well Plan Approval #		SW NE Section Township Range		or Govt Lot # 15 2 N 16 E				2. Well Type New Well					
				Approval Date (mm-dd-yyyy)						of previous unique well # constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity 1.5		Reason for replaced or reconstructed well ?											
3. Well serves 1 # of HOME				Hicap Well ? No		Construction Type Drilled											
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ? No													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
9		Surface		65		Yes Rotary - Mud Circulation		No		K Z		K-COBBLER/BOULDERS Z-W/COBBLES/BOULDERS		Surface		65	
						No Rotary - Air		No									
						No Rotary - Air & Foam		No									
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						No Cable-tool Bit ___ in. dia...		No									
						No Dual Rotary		No									
						No Temp. Outer Casing ___ in. dia											
						No Removed? ___ depth ft. (If NO explain on back side)											
6. Casing, Liner, Screen												9. Static Water Level		11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		32 ft. below ground surface		14 in. above grade					
5		PVC SDR21 F480 SOLVENT WELD				Surface		60		10. Pump Test		Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 45 ft. below surface		Disinfected ? Yes					
5		STAINLESS STEEL #20				60		65		Pumping at 20 GP M for 2 Hrs.		Capped ? Yes					
										Pumping Method ? Airlift							
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? No					
Method TREMIE PIPE PUMPED																	
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement				Filled & Sealed Well(s) as needed? No							
GRANULAR BENTONITE CETCO MIX		Surface		60		8 S											
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												LG		6994		04-09-2026	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Collector - Sanitary		60

Comment:

Created On: 04-15-2026

Updated On: 05-08-2026

Review Status: APPROVED