Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM605

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SHODEEN			Phone #
Mailing Address: 77 N 1ST			
City: GENEVA	State: IL	Zip Code: 60134	
County: Walworth	Co. Permit #:	Notification #: 10216999301	Completed: 04-09-2026

Well Constructor (Business Name): GEHRING, LANCE M	Lic. #: 6994	Facility ID # (Public Wells):	
Address: LANCE GEHRING WELL DRILLING 8820 KAROW RD TWIN LAKES WI 53181		Well Plan Approval #:	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.5	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
City of DELAVAN

Fire # (if avail.):

Street Address or Road Name and Number: 3987 WHITING

Subdivision Name	Lot #	Block #
	42	

Latitude / Longitude in Decimal Degree (DD): 42.6346 °N -88.5873 °W
Method Code: GPS008

SW NE or Govt Lot #	Section	Township	Range
	15	2 N	16 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	65

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		K	Z	K-COBBLES/BOULDERS Z-W/COBBLES/BOULDERS	Surface	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC SDR21 F480 SOLVENT WELD	Surface	60
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	STAINLESS STEEL #20	60	65

7. Grout or Other Sealing Material
Method TREMIE PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE CETCO MIX	Surface	60	8 S

9. Static Water Level
32 ft. below ground surface

10. Pump Test
Pumping level 45 ft. below surface
Pumping at 20 GP M for 2 Hrs.
Pumping Method ? Airlift

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
LG	6994	04-09-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Collector - Sanitary		60

Comment:

Created On: 04-15-2026 Updated On: 05-08-2026 Review Status: APPROVED