

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM606		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SHODEEN						Phone #									
Mailing Address 77 N 1ST						City of DELAVAN									
City GENEVA						State IL		Zip Code 60134							
County Walworth		Co. Permit #		Notification # 10218325601		Completed 04-10-2026		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) GEHRING, LANCE M				Lic. # 6994		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.6317 °N -88.5814 °W				Method Code GPS008	
Address LANCE GEHRING WELL DRILLING 8820 KAROW RD TWIN LAKES WI 53181				Well Plan Approval #		NE SE		Section 15		Township 2 N		Range 16 E			
				Approval Date (mm-dd-yyyy)		or Govt Lot #									
Hicap Permanent Well #		Common Well #		Specific Capacity 0		2. Well Type New Well						of previous unique well #		constructed in	
3. Well serves 1 # of HOME Private,potable Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No		Hicap Potable ? No		Reason for replaced or reconstructed well ?					
										Construction Type Drilled					
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
9		Surface		57		Yes Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
K Z		K-COBBLER/BOULDERS Z-W/COBBLES/BOULDERS		Surface		57									
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
5		PVC SDR21 F480 SOLVENT WELD				Surface		51							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5		STAINLESS STEEL #20				51		57							
7. Grout or Other Sealing Material															
Method TREMIE PIPE - PUMPED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE CETCO MIX		Surface		57		8 S									
9. Static Water Level															
20 ft. below ground surface															
10. Pump Test															
Pumping level 40 ft. below surface															
Pumping at 20 GP M for 2 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
14 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
Lic #		Date Signed													
LG		6994		04-15-2026											
Drill Rig Operator		Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Sewer - Collector - Sanitary		60

Comment:

Created On: 04-15-2026

Updated On: 05-08-2026

Review Status: APPROVED