

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM607		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner SOMMERFIELD					Phone #			1. Well Location				Fire # (if avail.)			
Mailing Address W236 S5764 ELM TREE								City of WAUKESHA							
City WAUKESHA					State WI		Zip Code 53189		Street Address or Road Name and Number				W236 S5764 ELM TREE		
County Waukesha		Co. Permit #		Notification # 10223066201		Completed 04-13-2026		Subdivision Name			Lot #		Block #		
Well Constructor (Business Name) GEHRING, LANCE M				Lic. # 6994		Facility ID # (Public Wells)			Latitude / Longitude in Decimal Degree (DD) 42.9401 °N -88.2208 °W			Method Code GPS008			
Address LANCE GEHRING WELL DRILLING 8820 KAROW RD TWIN LAKES WI 53181				Well Plan Approval #			SE NW		Section 35		Township 6 N		Range 19 E		
				Approval Date (mm-dd-yyyy)			or Govt Lot #								
Hicap Permanent Well #			Common Well #			Specific Capacity 0			2. Well Type New Well						
									of previous unique well # constructed in						
									Reason for replaced or reconstructed well ?						
									Construction Type Drilled						
3. Well serves 1 # of HOME														Hicap Well ? No	
Private, potable														Hicap Property ? No	
Heat Exchange ___ # of drillholes														Hicap Potable ? No	
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
9		Surface		145		Yes Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)				To (ft.)			
		C Z		C-CLAY Z-W/COBBLES/BOULDERS				Surface				138			
		Y G		Y-SAND & GRAVEL G-W/GRAVEL/STONES				138				145			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification				From (ft.)		To (ft.)		11. Well Is					
		Manufacturer & Method of Assembly								14 in. above grade					
5		PVC SDR21 F480 SOLVENT WELD				Surface		140		10. Pump Test					
										Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Disinfected ? Yes					
5		STAINLESS STEEL #20				140		145		Capped ? Yes					
7. Grout or Other Sealing Material															
Method TREMIE PIPE PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No					
GRANULAR BENTONITE CETCO MIX				Surface		140		15 S		Filled & Sealed Well(s) as needed? No					
13. Constructor / Supervisory Driller															
LG				Lic # 6994		Date Signed 04-13-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100

Comment:

Created On: 04-15-2026

Updated On: 05-08-2026

Review Status: APPROVED