

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM609		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner STASIK				Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address W2484 TROY HILL						Town of EAST TROY									
City EAST TROY				State WI		Zip Code 53120									
County Walworth		Co. Permit #		Notification # 10224246901		Completed 04-14-2026		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) GEHRING, LANCE M				Lic. # 6994		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.7777 °N -88.4246 °W				Method Code GPS008	
Address LANCE GEHRING WELL DRILLING 8820 KAROW RD TWIN LAKES WI 53181				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 30 4 N 18 E									
Hicap Permanent Well #				Common Well #		Specific Capacity 0				2. Well Type New Well					
3. Well serves 1 # of HOME				Hicap Well ? No		of previous unique well #				constructed in					
Private, potable				Hicap Property ? No		Reason for replaced or reconstructed well ?									
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
9		Surface		65		Yes Rotary - Mud Circulation				No					
						No Rotary - Air				No					
						No Rotary - Air & Foam				No					
						No Drill-Through Casing Hammer									
						No Reverse Rotary									
						No Cable-tool Bit ___ in. dia...				No					
						No Dual Rotary				No					
						No Temp. Outer Casing ___ in. dia									
						No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
C C		C-CLAY C-CLAYEY				Surface		58							
G G		G-GRAVEL/STONES G-W/GRAVEL/STONES				58		65							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
5		PVC SDR21 F480 SOLVENT WELD				Surface		60							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
5		STAINLESS STEEL #20				60		65							
7. Grout or Other Sealing Material															
Method TREMIE PIPE PUMPED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE CETCO MIX		Surface		60		6 S									
9. Static Water Level															
11 ft. below ground surface															
10. Pump Test															
Pumping level 25 ft. below surface															
Pumping at 20 GP M for 2 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
14 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
LG				6994		04-15-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75

Comment:

Created On: 04-15-2026

Updated On: 05-08-2026

Review Status: APPROVED