Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM609

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: STASIK	Phone #
Mailing Address: W2484 TROY HILL	
City: EAST TROY	State: WI — Zip Code: 53120
County: Walworth	Co. Permit #: — Notification #: 10224246901 — Completed: 04-14-2026
Well Constructor (Business Name): GEHRING, LANCE M	Lic. #: 6994 — Facility ID # (Public Wells):
Address: LANCE GEHRING WELL DRILLING 8820 KAROW RD, TWIN LAKES WI 53181	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #: — Common Well #: — Specific Capacity: 1.4	

1. Well Location

Town of EAST TROY

Fire # (if avail.):

Street Address or Road Name and Number: W2484 TROY LN

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.7777 °N -88.4246 °W — Method Code: GPS008

NW SW or Govt Lot # — Section: 30 — Township: 4 N — Range: 18 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	65

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C	C	C-CLAY C-CLAYEY	Surface	58
		G	G	G-GRAVEL/STONES G-W/GRAVEL/STONES	58	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	PVC SDR21 F480 SOLVENT WELD	Surface	60
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	STAINLESS STEEL #20	60	65

7. Grout or Other Sealing Material

Method TREMIE PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE CETCO MIX	Surface	60	6 S

9. Static Water Level

11 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
LG	6994	04-15-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75

Comment:

Created On: 04-15-2026 Updated On: 10-15-2026 Review Status: APPROVED