Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM610

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: DERGENE, DAVID			Phone #
Mailing Address: 7032 CR J			
City: VALDERS	State: WI	Zip Code: 54247	
County: Manitowoc	Co. Permit #:	Notification #: 10223478901	Completed: 04-14-2026

Well Constructor (Business Name): GROUND SOURCE LLC	Lic. #: 9443	Facility ID # (Public Wells):	
Address: 3671 MONROE ROAD DEPERE WI 54115		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.4	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of LIBERTY				Fire # (if avail.): 7032
Street Address or Road Name and Number: CR J				
Subdivision Name:			Lot #:	Block #:
Latitude / Longitude in Decimal Degree (DD): 44.0131 °N -87.8835 °W				Method Code: GPS008
NE SE or Govt Lot #:	Section: 20	Township: 18 N	Range: 22 E	

2. Well Type New Well
of previous unique well # constructed in
Reason for replaced or reconstructed well ?
Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	150
6	150	180

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	Y-SAND & GRAVEL	Surface	75
Z	Z-CLAY & GRAVEL	75	130
P	P-HARDPAN	130	150
L	L-LIMESTONE/DOLOMITE	150	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PLN END BLK STEEL WELDED 18.97.280 A53 NUCOR	Surface	150
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
37 ft. below ground surface

10. Pump Test
Pumping level 100 ft. below surface
Pumping at 25 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HIGH SOLIDS BENTONITE GROUT	Surface	150	8 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TS	6667	04-15-2026
Drill Rig Operator	Lic or Reg #	Date Signed
MS		04-15-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Ditch or Culvert		15
			Septic or Holding, or POWTS Tank		50

Comment:

Variance ID	Variance or Exception Type	Date	Reason
84607	Landfill Variance	04/03/2026	PROPERTY IS WITHIN 1200'

Created On: 04-15-2026 Updated On: 10-15-2026 Review Status: APPROVED