Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM631

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NOSKOWIAK, CHARLES	Phone #: (715)627-4203
Mailing Address: W12216 ST HWY 64	
City: ANTIGO	State: WI — Zip Code: 54409
County: Langlade	Co. Permit #:
Notification #: 10198704701	Completed: 04-15-2026
Well Constructor (Business Name): DREWS WELL DRILLING INC	Lic. #: 5900
Facility ID # (Public Wells):	
Address: 170001 RINGLE AVE, RINGLE WI 54471	
Well Plan Approval #:	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of ACKLEY

Fire # (if avail.):

Street Address or Road Name and Number: W12216 ST HWY 64

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 45.1475 °N -89.2659 °W — Method Code: GPS008

SW SE or Govt Lot #: | Section: 20 | Township: 31 N | Range: 10 E

2. Well Type Replacement

of previous unique well #: | constructed in:

Reason for replaced or reconstructed well ?: HIGH NITRATES

Construction Type: Drilled

3. Well serves # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	60
6	60	245

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
Yes	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 26depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y		Y-SAND & GRAVEL	Surface	18
	S	Q	H	S-SOFT/LOOSE Q-GRANITE H-SHALEY	18	26
		Q		Q-GRANITE	26	245

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B 18.97LBS/FT WELDED	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PRESSURE PACKER

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	60	15 S

9. Static Water Level

6 ft. below ground surface

10. Pump Test

Pumping level 220 ft. below surface

Pumping at 3.5 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

17 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJD	5686	05-03-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		84	POWTS dispersal component (soil absorption unit or mound)		165
			Ditch or Culvert		35

Comment:

Created On: 04-15-2026 Updated On: 05-19-2026 Review Status: APPROVED