Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM632

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TAYLOR MIKE			Phone #
Mailing Address: 21010 FREEDOM DR			
City: FREDERIC	State: WI	Zip Code: 54837	
County: Burnett	Co. Permit #:	Notification #: 10225183401	Completed: 04-15-2026

1. Well Location

Fire # (if avail.): 21010

Town of TRADE LAKE

Street Address or Road Name and Number: FREEDOM DR

Subdivision Name: | Lot #: | Block #:

Well Constructor (Business Name): AQUA-SERVICE INC	Lic. #: 6083	Facility ID # (Public Wells):	Latitude / Longitude in Decimal Degree (DD): 45.67916 °N -92.54795 °W
Address: 1388 24 1/2 ST CAMERON WI 54822		Well Plan Approval #:	Method Code: SCR002
		Approval Date (mm-dd-yyyy):	SW NW or Govt Lot #: Section: 24 Township: 37 N Range: 18 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: LOW PRODUCTION

Construction Type: Drilled

Hicap Permanent Well #	Common Well #	Specific Capacity: 7.5

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	60

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	S		T-TAN/BROWN V-NON-CAVING S-SAND	Surface	25
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	25	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 19#/FT ASTM A53B NUCORE WELDED	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	.015 STAINLESS CONT SLOT - STAINLESS STEEL	57	60

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

9. Static Water Level

25 ft. below ground surface

10. Pump Test

Pumping level 27 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? No

PUMP INSTALLER WILL DO

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	6562	04-23-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
PH	7429	04-23-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	65	Septic or Holding, or POWTS Tank	>	27

Comment:

Created On: 04-15-2026 Updated On: 10-15-2026 Review Status: APPROVED