Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM633

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WCE, LLC	Phone #
Mailing Address: 10695 COUNTY ROAD V	
City: MARSHFIELD	State: WI — Zip Code: 54449
County: Wood	Co. Permit #: w26003 — Notification #: 10216084101 — Completed: 04-08-2026
Well Constructor (Business Name): HEEG WELL AND PUMP LLC	Lic. #: 7855 — Facility ID # (Public Wells):
Address: 5069 TRESTIK DR, AUBURNDALE WI 54412	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0

1. Well Location

Town of CAMERON	Fire # (if avail.): 9318
Street Address or Road Name and Number: MILL CREEK DR	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.6132 °N -90.1811 °W	Method Code: GPS008
SE SE or Govt Lot #:	Section: 30 — Township: 25 N — Range: 3 E

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of SHOP

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	202

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	C	S	T-TAN/BROWN Q-CAVING C-CLAY S-SANDY	Surface	36
P	H	N		P-PINK H-HARD/FIRM N-SANDSTONE	36	39
I	H	N	C	I-WHITE H-HARD/FIRM N-SANDSTONE C-CLAYEY	39	42
R	H	Q		R-RED H-HARD/FIRM Q-GRANITE	42	202

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STANDARD STEEL, ASTM A53,NTP-TRI ,WELDED JOINT	Surface	36
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

4 ft. below ground surface

10. Pump Test

Pumping level 202 ft. below surface

Pumping at 1.5 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
CH	7316	04-15-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		30

Comment:

Created On: 04-15-2026 Updated On: 05-08-2026 Review Status: APPROVED