

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM633		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner WCE, LLC					Phone #			1. Well Location				Fire # (if avail.)			
Mailing Address 10695 COUNTY ROAD V								Town of CAMERON				9318			
City MARSHFIELD					State WI		Zip Code 54449		Street Address or Road Name and Number				MILL CREEK DR		
County Wood		Co. Permit # w26003		Notification # 10216084101		Completed 04-08-2026		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) HEEG WELL AND PUMP LLC					Lic. # 7855		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.6132 °N -90.1811 °W				Method Code GPS008		
Address 5069 TRESTIK DR AUBURNDALE WI 54412					Well Plan Approval #		SE SE		Section 30		Township 25 N		Range 3 E		
					Approval Date (mm-dd-yyyy)		or Govt Lot #								
Hicap Permanent Well #			Common Well #		Specific Capacity 0		2. Well Type New Well								
3. Well serves 1 # of SHOP Private, potable Heat Exchange ___ # of drillholes							Hicap Well ? No		of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled						
							Hicap Property ? No								
							Hicap Potable ? No								
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.) 6		From (ft.) Surface		To (ft.) 202		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology					
						No Rotary - Mud Circulation No Yes Rotary - Air Yes No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				Geology Codes Type, Caving/Noncaving, Color, Hardness, etc... From (ft.) To (ft.) T Q C S T-TAN/BROWN Q-CAVING C-CLAY S-SANDY Surface 36 P H N P-PINK H-HARD/FIRM N-SANDSTONE 36 39 I H N C I-WHITE H-HARD/FIRM N-SANDSTONE C-CLAYEY 39 42 R H Q R-RED H-HARD/FIRM Q-GRANITE 42 202					
6. Casing, Liner, Screen															
Dia. (in.) 6		Material, Weight, Specification STANDARD STEEL, ASTM A53,NTP-TRI, WELDED JOINT				From (ft.) Surface		To (ft.) 36		9. Static Water Level					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		10. Pump Test					
										4 ft. below ground surface 12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes					
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		11. Well Is							
GRANULAR BENTONITE		Surface				2 S		Filled & Sealed Well(s) as needed? No 12. Notified Owner of need to fill & seal ? No							
13. Constructor / Supervisory Driller															
CH		Lic # 7316		Date Signed 04-15-2026		13. Constructor / Supervisory Driller									
Drill Rig Operator		Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		30

Comment:

Created On: 04-15-2026

Updated On: 05-08-2026

Review Status: APPROVED