Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM634

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MORRISON SARA	Phone #
Mailing Address: 125 DEPOT RD	
City: OSCEOLA	State: WI Zip Code: 54020
County: Burnett	Co. Permit #:	Notification #: 10225187601	Completed: 04-15-2026
Well Constructor (Business Name): AQUA-SERVICE INC	Lic. #: 6083
Address: 1388 24 1/2 ST CAMERON WI 54822	
Hicap Permanent Well #	Common Well #	Specific Capacity: 7.5

1. Well Location

Town of ANDERSON

Fire # (if avail.): 20469

Street Address or Road Name and Number: RANGE LINE RD

Subdivision Name | Lot # | Block #

Latitude / Longitude in Decimal Degree (DD): 45.6604 °N -92.6549 °W

Method Code: SCR002

Facility ID # (Public Wells)

Well Plan Approval #

Approval Date (mm-dd-yyyy)

SE or Govt Lot #	SE	Section: 25	Township: 37 N	Range: 19 W

2. Well Type Replacement

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: LOW PRODUCTION

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	40

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	V	X		T-TAN/BROWN V-NON-CAVING X-SAND & CLAY	Surface	15
T	V	Y		T-TAN/BROWN V-NON-CAVING Y-SAND & GRAVEL	15	23
T	Q	Y		T-TAN/BROWN Q-CAVING Y-SAND & GRAVEL	23	40

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW STEEL 19#/FT ASTM A53B NUCORE WELDED	Surface	37
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	.015 STAINLESS CONT SLOT - STAINLESS STEEL	37	40

7. Grout or Other Sealing Material

Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		1 S

9. Static Water Level

23 ft. below ground surface

10. Pump Test

Pumping level 25 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH	6562	05-12-2026
Drill Rig Operator	Lic or Reg #	Date Signed
RK	7429	05-12-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60	Septic or Holding, or POWTS Tank	>	40

Comment:

Created On: 04-15-2026 Updated On: 10-15-2026 Review Status: APPROVED