

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM635		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MILLER, ABIGAIL					Phone #		1. Well Location Fire # (if avail.) N6585								
Mailing Address 327 ALDER STREET															
City BLACK RIVER FALLS			State WI	Zip Code 54615		Town of ADAMS Street Address or Road Name and Number RYE BLUFF RD									
County Jackson	Co. Permit # 026090-1	Notification # 10224628101		Completed 04-15-2026		Subdivision Name			Lot #	Block #					
Well Constructor (Business Name) HEEG WELL AND PUMP LLC			Lic. # 7855	Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.3058 °N -90.87 °W			Method Code GPS008						
Address 5069 TRESTIK DR AUBURNDALE WI 54412			Well Plan Approval #		NW NE Section Township Range or Govt Lot # 16 21 N 4 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled								
			Approval Date (mm-dd-yyyy)												
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5											
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No											
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)	From (ft.)	To (ft.)	Upper Enlarged Drillhole			Lower Open Bedrock			Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)	To (ft.)
10	Surface	58	<u>No</u> Rotary - Mud Circulation			<u>No</u>			T	Q	C	S	T-TAN/BROWN Q-CAVING C-CLAY S-SANDY	Surface	16
6	58	102	<u>Yes</u> Rotary - Air			<u>Yes</u>			T	H	N	H	T-TAN/BROWN H-HARD/FIRM N-SANDSTONE H-SHALEY	16	65
			<u>No</u> Rotary - Air & Foam			<u>No</u>			G	H	H	N	G-GRAY H-HARD/FIRM H-SHALE N-W/SANDSTONE	65	102
			<u>No</u> Drill-Through Casing Hammer												
			<u>No</u> Reverse Rotary												
			<u>No</u> Cable-tool Bit ___ in. dia...			<u>No</u>									
			<u>No</u> Dual Rotary			<u>No</u>									
			<u>Yes</u> Temp. Outer Casing 10in. dia												
			<u>Yes</u> Removed? 17depth ft. (If NO explain on back side)												
6. Casing, Liner, Screen												8. Geology			
Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)	To (ft.)	9. Static Water Level 58 ft. below ground surface			11. Well Is 24 in. above grade						
6	STANDARD STEEL, ASTM A53,NTP-TRI, WELDED JOINT			Surface	58	10. Pump Test Pumping level 102 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ? Airlift			Developed ? Yes Disinfected ? Yes Capped ? Yes						
Dia. (in.)	Screen type, material & slot size			From (ft.)	To (ft.)										
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED															
Kind of Sealing Material			From (ft.)	To (ft.)	# Sacks Cement		12. Notified Owner of need to fill & seal ? No Filled & Sealed Well(s) as needed? No								
NEAT CEMENT GROUT			Surface	58	40 S										
13. Constructor / Supervisory Driller												Lic #	Date Signed		
CH												7316	04-15-2026		
Drill Rig Operator												Lic or Reg #	Date Signed		

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		80	POWTS dispersal component (soil absorption unit or mound)		80

Comment:

Created On: 04-15-2026

Updated On: 05-08-2026

Review Status: APPROVED