Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM635

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MILLER, ABIGAIL	Phone #
Mailing Address: 327 ALDER STREET	
City: BLACK RIVER FALLS	State: WI — Zip Code: 54615

County	Co. Permit #	Notification #	Completed
Jackson	026090-1	10224628101	04-15-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
HEEG WELL AND PUMP LLC	7855	

Address: 5069 TRESTIK DR
AUBURNDALE WI 54412

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.5

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of ADAMS

Fire # (if avail.) N6585

Street Address or Road Name and Number: RYE BLUFF RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.3058 °N -90.87 °W	GPS008

NW NE or Govt Lot #	Section	Township	Range
	16	21 N	4 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	58
6	58	102

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 17depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T	Q	C	S	T-TAN/BROWN Q-CAVING C-CLAY S-SANDY	Surface	16
T	H	N	H	T-TAN/BROWN H-HARD/FIRM N-SANDSTONE H-SHALEY	16	65
G	H	H	N	G-GRAY H-HARD/FIRM H-SHALE N-W/SANDSTONE	65	102

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STANDARD STEEL, ASTM A53,NTP-TRI ,WELDED JOINT	Surface	58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	58	40 S

9. Static Water Level
58 ft. below ground surface

10. Pump Test
Pumping level 102 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
CH	7316	04-15-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		80	POWTS dispersal component (soil absorption unit or mound)		80

Comment:

Created On: 04-15-2026 Updated On: 05-08-2026 Review Status: APPROVED