Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM638

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ROHDE, TODD	Phone #: (715)613-6485
Mailing Address: W5257 TWENTY SIX RD.	
City: GREENWOOD	State: WI — Zip Code: 54437
County: Clark	Co. Permit #:
Notification #: 10202278001	Completed: 04-06-2026
Well Constructor (Business Name): BRUNNER WELL DRILLING LLC	Lic. #: 6469
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 303 S 8TH ST MEDFORD WI 54451	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.1	

1. Well Location

Town of EATON

Fire # (if avail.):

Street Address or Road Name and Number: W5257 TWENTY SIX RD.

Subdivision Name: | Lot #: | Block #:

Latitude / Longitude in Decimal Degree (DD): 44.7122 °N -90.5757 °W

Method Code: SCR002

NW or Govt Lot #: NW | Section: 25 | Township: 26 N | Range: 2 W

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: DUG WELL

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	19
6	19	200

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		I-SOIL-ORGANIC	Surface	2
T		Z		T-TAN/BROWN Z-CLAY & GRAVEL	2	50
T		Y	U	T-TAN/BROWN Y-SAND & GRAVEL U-MUDDY OR MURKY	50	60
R		H		R-RED H-SHALE	60	62
T	X	N	H	T-TAN/BROWN X-LENSED/STREAKED/LAYERED N-SANDSTONE H-SHALEY	62	74
T	D	Q		T-TAN/BROWN D-DECOMPOSED/WEATHERED Q-GRANITE	74	86
G	H	Q		G-GRAY H-HARD/FIRM Q-GRANITE	86	200

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL, T&C, A53B, 19.45#/FT., WHEATLAND, .280 WALL	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD & CUTTINGS	Surface	19	

9. Static Water Level	11. Well Is
37 ft. below ground surface	30 in. above grade
10. Pump Test	Developed ? Yes
Pumping level 105 ft. below surface	Disinfected ? Yes
Pumping at 9 GP M for 28 Hrs.	Capped ? Yes
Pumping Method ? Test Pump	

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? No

PUMP INSTALLER TO DO.

13. Constructor / Supervisory Driller	Lic #	Date Signed
JWB	4379	04-17-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Building Sanitary	>	50	Septic or Holding, or POWTS Tank	>	75

Comment:

Rehab Type	Rehab Date	Result Text
Hydrofracture	04/10/2026	40 G.P.H.

Created On: 04-16-2026 Updated On: 05-08-2026 Review Status: APPROVED