

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM645		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner BERNADINE MIKA (IHS)					Phone #		1. Well Location Fire # (if avail.) 47949						
Mailing Address 47949 BEASER RD													
City ASHLAND			State WI		Zip Code 54806		Town of GINGLES Street Address or Road Name and Number BEASER RD						
County Ashland		Co. Permit # 1		Notification # 10226647601		Completed 04-16-2026		Subdivision Name			Lot # Block #		
Well Constructor (Business Name) NEHLS & WEBSTER WELL DRILLING				Lic. # 6076		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 46.51592 °N -90.88605 °W			Method Code SCR002		
Address 1901 APACHE LN RHINELANDER WI 54501				Well Plan Approval #		NE NE		Section 32		Township 47 N		Range 4 W	
				Approval Date (mm-dd-yyyy)		or Govt Lot #							
Hicap Permanent Well #			Common Well #		Specific Capacity 0.3		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? OLD 3" WELL						
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No		Hicap Property ? No		Hicap Potable ? No		Construction Type Drilled			
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole			Lower Open Bedrock				
10		Surface		65		Yes Rotary - Mud Circulation			No				
6		65		188		No Rotary - Air			No				
						No Rotary - Air & Foam			No				
						No Drill-Through Casing Hammer							
						No Reverse Rotary							
						No Cable-tool Bit ___ in. dia...			No				
						No Dual Rotary			No				
						No Temp. Outer Casing ___ in. dia							
						No Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...			From (ft.)			To (ft.)				
Z			Z-CLAY & GRAVEL			Surface			182				
N			N-SANDSTONE			182			188				
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.)		To (ft.)						
6		MARIUCCI PE 18.97 A53			Surface		186						
Dia. (in.)		Screen type, material & slot size			From (ft.)		To (ft.)						
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material			From (ft.)		To (ft.)		# Sacks Cement						
HIGH YIELD BENTONITE			Surface		65		7 S						
9. Static Water Level 103 ft. below ground surface													
10. Pump Test Pumping level 160 ft. below surface Pumping at 15 GP M for 1 Hrs. Pumping Method ? Test Pump													
11. Well Is 24 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes													
12. Notified Owner of need to fill & seal ? Yes													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller													
Lic #			Date Signed										
PW			156			04-27-2026							
Drill Rig Operator			Lic or Reg #			Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		45	POWTS dispersal component (soil absorption unit or mound)		60

Comment:

Created On: 04-16-2026

Updated On: 06-04-2026

Review Status: APPROVED