Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM645

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BERNADINE MIKA (IHS)	Phone #
Mailing Address: 47949 BEASER RD	
City: ASHLAND	State: WI — Zip Code: 54806
County: Ashland	Co. Permit #: 1 — Notification #: 10226647601 — Completed: 04-16-2026
Well Constructor (Business Name): NEHLS & WEBSTER WELL DRILLING	Lic. #: 6076 — Facility ID # (Public Wells)
Address: 1901 APACHE LN, RHINELANDER WI 54501	Well Plan Approval # / Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 0.3

1. Well Location

Town of GINGLES	Fire # (if avail.): 47949
Street Address or Road Name and Number: BEASER RD	
Subdivision Name	Lot # — Block #
Latitude / Longitude in Decimal Degree (DD): 46.51592 °N -90.88605 °W	Method Code: SCR002
NE NE or Govt Lot #	Section: 32 — Township: 47 N — Range: 4 W

2. Well Type Replacement
of previous unique well # — constructed in
Reason for replaced or reconstructed well ?: OLD 3" WELL
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	65
6	65	188

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Z	Z-CLAY & GRAVEL	Surface	182
N	N-SANDSTONE	182	188

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	MARIUCCI PE 18.97 A53	Surface	186
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
HIGH YIELD BENTONITE	Surface	65	7 S

9. Static Water Level
103 ft. below ground surface

10. Pump Test
Pumping level 160 ft. below surface
Pumping at 15 GP M for 1 Hrs.
Pumping Method ? Test Pump

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? Yes
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
PW	156	04-27-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		45	POWTS dispersal component (soil absorption unit or mound)		60

Comment:

Created On: 04-16-2026 Updated On: 06-04-2026 Review Status: APPROVED