Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM647

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NEWELL, GEORGE	Phone #
Mailing Address: PO BOX 580	
City: STUREGEON BAY	State: WI — Zip Code: 54235
County: Door	Co. Permit #:
Notification #: 10223454601	Completed: 04-14-2026
Well Constructor (Business Name): HINTZKE WELL DRILLING INC	Lic. #: 267
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: N5072 HINTZKE RD NEW LONDON WI 54961-9802	Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0.5	

1. Well Location

Town of EGG HARBOR	Fire # (if avail.): 5985
Street Address or Road Name and Number: LADY SLIPPER RD	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.9651 °N -87.3705 °W	Method Code: SCR002

NE	NW	Section	Township	Range
or Govt Lot #		29	29 N	26 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	134
6	134	165

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
Yes	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
U		I	G	U-BLUE I-SOIL-ORGANIC G-W/GRAVEL/STONES	Surface	3
T		L		T-TAN/BROWN L-LIMESTONE/DOLOMITE	3	165

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	US WHEATLAND PE 280 WALL A53 WELD	Surface	136
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

1 ft. above ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 20 GP M for 2 Hrs.

Pumping Method ? Airlift

11. Well Is

24 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material

Method BRADENHEAD

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	133	36 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JCH	6935	04-24-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
AMW	8803	04-24-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment: VERBAL WAS GIVEN FROM BEN DEGNER TO INSTALL 130 FT OF CASING BEFORE VARIANCE WAS GRANTED

Created On: 04-16-2026 Updated On: 05-29-2026 Review Status: APPROVED