Well Construction Report
WISCONSIN UNIQUE WELL NUMBER: ACM651

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	WESTCOMB, NICHOLAS & DANIELLE
Phone #	
Mailing Address	8141 FOLEY RD
City	CALEDONIA
State	WI
Zip Code	53189
County	Adams
Co. Permit #	
Notification #	10001182901
Completed	04-15-2026
Well Constructor (Business Name)	MARSHALL WELL DRILLING CORP
Lic. #	6946
Facility ID # (Public Wells)	
Address	3774 ST RD 13 WISCONSIN DELLS WI 53965-8906
Well Plan Approval #	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	
Common Well #	
Specific Capacity	3.3

1. Well Location

Town of STRONGS PRAIRIE	Fire # (if avail.) 1913
Street Address or Road Name and Number	19TH PASS
Subdivision Name	TIMBER SHORES
Lot #	26
Block #	
Latitude / Longitude in Decimal Degree (DD)	43.9798 °N -89.9547 °W
Method Code	GPS008
NW or Govt Lot #	NW
Section	6
Township	17 N
Range	5 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9.875	Surface	75
6	75	78

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
Yes	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? 23depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	23
	S	N		S-SOFT/LOOSE N-SANDSTONE	23	75
	H	N		H-HARD/FIRM N-SANDSTONE	75	78

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. STEEL PIPE ASTM A-53 GR.B 18.97 LBS/FT WHEATLAND STEEL	Surface	75
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

16 ft. below ground surface

10. Pump Test

Pumping level 22 ft. below surface

Pumping at 20 GP M for 72 Hrs.

Pumping Method ? Test Pump

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	75	28 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JLJ	7213	04-20-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RGW	7349	04-20-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	200
Sewer - Collector - Sanitary	>	100
Building Drain - Sanitary	>	32
Sewer - Building Sanitary	>	34

Comment:

Created On: 04-16-2026 Updated On: 05-12-2026 Review Status: APPROVED