

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM652		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner RETLAW CONTRACTING LLC						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 1049 200TH ST						Town of APPLE RIVER						1019			
City DRESSER						State WI		Zip Code 54009				Street Address or Road Name and Number 135TH AVE			
County Polk		Co. Permit #		Notification # 10226856501		Completed 04-29-2026		Subdivision Name				Lot # Block #			
Well Constructor (Business Name) TIM BUTTERFIELD DRILLING INC				Lic. # 6900		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.4035 °N -92.3695 °W				Method Code SCR002	
Address 395 REED ST SOMERSET WI 54025				Well Plan Approval #		SE NE Section Township Range or Govt Lot # 29 34 N 16 W		2. Well Type New Well				of previous unique well # constructed in			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5				Reason for replaced or reconstructed well ?					
3. Well serves 1 # of HOME				Hicap Well ? No		Private, potable				Hicap Property ? No					
Heat Exchange ___ # of drillholes				Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		140		No Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary Yes No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
G		G-GRAVEL/STONES				Surface		65							
C		C-CLAY				65		120							
N		N-SANDSTONE				120		140							
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW P&E BLK WELDED 18.97 LB/FT ASTM A53 NUCOR				Surface		120							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement									
GRANULAR BENTONITE		Surface		20		2 S									
9. Static Water Level															
40 ft. below ground surface															
10. Pump Test															
Pumping level 60 ft. below surface															
Pumping at 10 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
18 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller				Lic #		Date Signed									
TB				6901		04-29-2026									
Drill Rig Operator				Lic or Reg #		Date Signed									
NS				8774		04-29-2026									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)	>	25	POWTS dispersal component (soil absorption unit or mound)	>	50

Comment:

Created On: 04-16-2026

Updated On: 05-28-2026

Review Status: APPROVED