

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM653		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A	
Property Owner PORTSIDE				Phone #		1. Well Location				Fire # (if avail.)	
Mailing Address 810 S. LANSING						Town of GIBRALTAR				9196	
City STURGEON BAY				State WI		Zip Code 54235				Street Address or Road Name and Number EAGLE LEDGE	
County		Co. Permit #		Notification #		Completed		Subdivision Name		Lot #	
Door		1		10224453101		04-15-2026				Block #	
Well Constructor (Business Name) VAN DE YACHT LEO WELL DRILLING INC				Lic. # 6097		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 45.1176 °N -87.2376 °W		Method Code GPS008	
Address 1267 LAKEVIEW DR GREEN BAY WI 54313				Well Plan Approval #		NE SE Section Township Range or Govt Lot # 32 31 N 27 E		2. Well Type New Well			
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6		of previous unique well # constructed in			
3. Well serves 1 # of HOME				Hicap Well ? No		Reason for replaced or reconstructed well ?		Construction Type Drilled			
Private, potable				Hicap Property ? No							
Heat Exchange ___ # of drillholes				Hicap Potable ? No							
4. Potential Contamination Sources - ON REVERSE SIDE											
5. Drillhole Dimensions and Construction Method											
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology	
10		Surface		6		No Rotary - Mud Circulation		No		Geology Codes	
8		6		187		Yes Rotary - Air		Yes		Type, Caving/Noncaving, Color, Hardness, etc...	
6		187		222		No Rotary - Air & Foam		No		From (ft.) To (ft.)	
						No Drill-Through Casing Hammer				I SOIL-ORGANIC Surface 2	
						No Reverse Rotary				L L-LIMESTONE/DOLOMITE 2 222	
						No Cable-tool Bit ___ in. dia...		No			
						No Dual Rotary		No			
						Yes Temp. Outer Casing 8in. dia					
						Yes Removed? 6depth ft. (If NO explain on back side)					
6. Casing, Liner, Screen											
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is	
6		NEW BLACK STEEL PLAIN END WELDED ASTM A 53B 18 97# PER FT NUCOR PIPE				Surface		187		24 in. above grade	
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes	
										Disinfected ? Yes	
										Capped ? Yes	
7. Grout or Other Sealing Material											
Method BRADENHEAD											
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No			
NEAT CEMENT GROUT		Surface		187		50 S		Filled & Sealed Well(s) as needed? No			
13. Constructor / Supervisory Driller											
TLV		Lic #		Date Signed		6378		04-16-2026			
Drill Rig Operator		Lic or Reg #		Date Signed		8900		04-16-2026			
TEV											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	=	120	Septic or Holding, or POWTS Tank	=	75

Comment:

Created On: 04-16-2026

Updated On: 05-20-2026

Review Status: APPROVED