

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM658		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner TOMCZYK, CORY						Phone #		1. Well Location				Fire # (if avail.)			
Mailing Address 212318 STEPAN DR						Town of MOSINEE						212318			
City MOSINEE						State WI		Zip Code 54455				Street Address or Road Name and Number STEPAN DR.			
County Marathon		Co. Permit #		Notification # 10028545601		Completed 04-16-2026		Subdivision Name				Lot #		Block #	
Well Constructor (Business Name) HEEG WELL AND PUMP LLC				Lic. # 7855		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.7954 °N -89.7353 °W				Method Code GPS008	
Address 5069 TRESTIK DR AUBURNDALE WI 54412				Well Plan Approval #				SW NE		Section 25		Township 27 N		Range 6 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3				2. Well Type New Well					
3. Well serves 1 # of HOME				Hicap Well ? No				of previous unique well #				constructed in			
Private, potable				Hicap Property ? No				Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes				Hicap Potable ? No				Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
6		Surface		35		<u>No</u> Rotary - Mud Circulation <u>No</u> <u>No</u> Rotary - Air <u>No</u> <u>No</u> Rotary - Air & Foam <u>No</u> <u>Yes</u> Drill-Through Casing Hammer <u>No</u> Reverse Rotary <u>No</u> Cable-tool Bit ___ in. dia... <u>No</u> <u>No</u> Dual Rotary <u>No</u> <u>No</u> Temp. Outer Casing ___ in. dia <u>No</u> Removed? ___ depth ft. (If NO explain on back side)									
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
T		Y		T-TAN/BROWN Y-SAND & GRAVEL				Surface		34					
		G		G-GRAVEL/STONES				34		35					
		Q		Q-GRANITE				35		35					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		STANDARD STEEL, ASTM A53,NTP-TRI, WELDED JOINT				Surface		35							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method MOUNDED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
GRANULAR BENTONITE				Surface				2 S							
9. Static Water Level															
12 ft. below ground surface															
10. Pump Test															
Pumping level 20 ft. below surface															
Pumping at 10 GP M for 1 Hrs.															
Pumping Method ? Airlift															
11. Well Is															
24 in. above grade															
Developed ? Yes															
Disinfected ? Yes															
Capped ? Yes															
12. Notified Owner of need to fill & seal ? No															
Filled & Sealed Well(s) as needed? No															
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
CH				7316				04-16-2026							
Drill Rig Operator				Lic or Reg #				Date Signed							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		100	POWTS dispersal component (soil absorption unit or mound)		125

Comment:

Created On: 04-16-2026

Updated On: 05-08-2026

Review Status: APPROVED