Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM658

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: TOMCZYK, CORY	Phone #
Mailing Address: 212318 STEPAN DR	
City: MOSINEE	State: WI — Zip Code: 54455
County: Marathon	Co. Permit #: — Notification #: 10028545601 — Completed: 04-16-2026
Well Constructor (Business Name): HEEG WELL AND PUMP LLC	Lic. #: 7855 — Facility ID # (Public Wells):
Address: 5069 TRESTIK DR, AUBURNDALE WI 54412	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.3

1. Well Location

Town of MOSINEE	Fire # (if avail.): 212318
Street Address or Road Name and Number: STEPAN DR.	
Subdivision Name:	Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): 44.7954 °N -89.7353 °W	Method Code: GPS008
SW NE or Govt Lot #:	Section: 25 — Township: 27 N — Range: 6 E

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?:
Construction Type: Drilled

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	35

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Y	T-TAN/BROWN Y-SAND & GRAVEL	Surface	34
G	G-GRAVEL/STONES	34	35
Q	Q-GRANITE	35	35

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STANDARD STEEL, ASTM A53,NTP-TRI ,WELDED JOINT	Surface	35
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 20 ft. below surface
Pumping at 10 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		2 S

12. Notified Owner of need to fill & seal ? No
Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
CH	7316	04-16-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		100	POWTS dispersal component (soil absorption unit or mound)		125

Comment:

Created On: 04-16-2026 Updated On: 05-08-2026 Review Status: APPROVED