Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM659

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: CARPENTER, PATRICK			Phone #
Mailing Address: N820 CTY RD G			
City: CAMPBELLSPORT	State: WI	Zip Code: 53010	
County: Fond du Lac	Co. Permit #:	Notification #: 10205931301	Completed: 04-16-2026

Well Constructor (Business Name): STEFFES, DANIEL J	Lic. #: 6109	Facility ID # (Public Wells):	
Address: BADGER WELL DRLG N7900 LOCUST LN MT CALVARY WI 53057		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.1	

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location
Town of AUBURN

Fire # (if avail.): N820

Street Address or Road Name and Number: N820 CTY RD G

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 43.5693 °N -88.2145 °W				Method Code: GPS008
NE NW or Govt Lot #	Section: 27	Township: 13 N	Range: 19 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	185

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	43
		Z	S	Z-CLAY & GRAVEL S-SANDY	43	60
		L		L-LIMESTONE/DOLOMITE	60	185

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A 53 B EXL TUBE 6.625 X .280 EL 20 PLAIN END	Surface	60
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
17 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 25 GP M for 1 Hrs.
Pumping Method ? Airlift

11. Well Is
24 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface		4 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
DS	6109	04-16-2026
Drill Rig Operator	Lic or Reg #	Date Signed
GM	6835	04-16-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Septic or Holding, or POWTS Tank	=	62

Comment:

Created On: 04-16-2026 Updated On: 05-08-2026 Review Status: APPROVED