Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM660

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FRED KOHLS	Phone #
Mailing Address: S90W34244 HWY NN	
City: EAGLE	State: WI — Zip Code: 53119
County: Waukesha	Co. Permit #: — Notification #: 10215898301 — Completed: 04-12-2026
Well Constructor (Business Name): KRIZAN, KENNETH J	Lic. #: 6519 — Facility ID # (Public Wells):
Address: 23900 W OVERSON RD, UNION GROVE WI 53182-9659	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0

1. Well Location

Town of EAGLE

Fire # (if avail.):

Street Address or Road Name and Number: S90W34244 HWY NN

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): 42.8848 °N -88.4278 °W — Method Code: GPS008

or Govt Lot #	NE	NE	Section	Township	Range
			24	5 N	17 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves 1 # of GARAGE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	62
6	62	345

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
Yes	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	C-CLAY	Surface	3
L	L-LIMESTONE/DOLOMITE	3	57
H	H-SHALE	57	270
L	L-LIMESTONE/DOLOMITE	270	345

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NTP SCH 40 STEEL ASTM A 53 B FULL 20 WELDED	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

19 ft. below ground surface

10. Pump Test

Pumping level 320 ft. below surface

Pumping at 15 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	62	17 S

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
KK	6519	04-17-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 04-17-2026 Updated On: 05-08-2026 Review Status: APPROVED