

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM660		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner FRED KOHLS					Phone #			1. Well Location			Fire # (if avail.)		
Mailing Address S90W34244 HWY NN								Town of EAGLE					
City EAGLE					State WI		Zip Code 53119		Street Address or Road Name and Number			S90W34244 HWY NN	
County Waukesha		Co. Permit #		Notification # 10215898301		Completed 04-12-2026		Subdivision Name			Lot # Block #		
Well Constructor (Business Name) KRIZAN, KENNETH J				Lic. # 6519		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 42.8848 °N -88.4278 °W			Method Code GPS008		
Address 23900 W OVERSON RD UNION GROVE WI 53182-9659				Well Plan Approval #		NE NE Section Township Range or Govt Lot # 24 5 N 17 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled					
				Approval Date (mm-dd-yyyy)									
Hicap Permanent Well #			Common Well #		Specific Capacity 0								
3. Well serves 1 # of GARAGE				Hicap Well ? No									
Private, potable				Hicap Property ? No									
Heat Exchange ___ # of drillholes				Hicap Potable ? No									
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology			
10		Surface		62		No Rotary - Mud Circulation		No		Geology Codes C C-CLAY From (ft.) Surface To (ft.) 3			
6		62		345		No Rotary - Air		No		L L-LIMESTONE/DOLOMITE 3 57			
						No Rotary - Air & Foam		No		H H-SHALE 57 270			
						Yes Drill-Through Casing Hammer				L L-LIMESTONE/DOLOMITE 270 345			
						No Reverse Rotary							
						No Cable-tool Bit ___ in. dia...		No					
						No Dual Rotary		No					
						No Temp. Outer Casing ___ in. dia							
						No Removed? ___ depth ft. (If NO explain on back side)							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is			
6		NTP SCH 40 STEEL ASTM A 53 B FULL 20 WELDED				Surface		62		18 in. above grade			
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes			
										Disinfected ? Yes			
										Capped ? Yes			
7. Grout or Other Sealing Material													
Method TREMIE PIPE - PUMPED													
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No					
NEAT CEMENT GROUT		Surface		62		17 S		Filled & Sealed Well(s) as needed? No					
13. Constructor / Supervisory Driller													
Lic #		Date Signed											
KK		6519		04-17-2026									
Drill Rig Operator		Lic or Reg #		Date Signed									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 04-17-2026

Updated On: 05-08-2026

Review Status: APPROVED