

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM664		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner DOUG SHAFFER					Phone #		1. Well Location Fire # (if avail.) Town of MEENON Street Address or Road Name and Number 26492 BLUEBIRD TRAIL				Subdivision Name Lot # Block #								
Mailing Address 26492 BLUEBIRD TRL																			
City WEBSTER			State WI		Zip Code 54893														
County Burnett		Co. Permit #		Notification # 10229857701		Completed 04-23-2026													
Well Constructor (Business Name) MCCULLOUGH AND SONS				Lic. # 44		Facility ID # (Public Wells) Well Plan Approval #		Latitude / Longitude in Decimal Degree (DD)				Method Code							
								45.8776 °N -92.40168 °W				SCR002							
Address 20335 FOREST BOULEVARD NORTH FOREST LAKE MN 55025-9764				Approval Date (mm-dd-yyyy)		SW SW Section Township Range or Govt Lot # 7 39 N 16 W		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? Construction Type Drilled											
Hicap Permanent Well #		Common Well #		Specific Capacity 0															
3. Well serves 1 # of HOME Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		8. Geology Geology Codes Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
8		Surface		124		Yes Rotary - Mud Circulation No No Rotary - Air No No Rotary - Air & Foam No No Drill-Through Casing Hammer No Reverse Rotary No Cable-tool Bit ___ in. dia... No No Dual Rotary No No Temp. Outer Casing ___ in. dia No Removed? ___ depth ft. (If NO explain on back side)				I I-SOIL-ORGANIC Surface 5 S S-SAND 5 20 Z Z-CLAY & GRAVEL 20 110 Y Y-SAND & GRAVEL 110 124									
6. Casing, Liner, Screen												9. Static Water Level 42 ft. below ground surface				11. Well Is 12 in. above grade			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		10. Pump Test Pumping level 120 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ? Airlift				Developed ? Yes Disinfected ? Yes Capped ? Yes					
6		SDR21 F480				Surface		120											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)											
6		STAINLESS STEEL SCREEN 15 SLOT				0		114											
7. Grout or Other Sealing Material Method TREMIE PIPE - PUMPED												12. Notified Owner of need to fill & seal ? No							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed? No									
BENTONITE GROUT				Surface		114		10 S											
												13. Constructor / Supervisory Driller Lic # Date Signed DM 72 04-27-2026 Drill Rig Operator Lic or Reg # Date Signed DAN 7343 04-27-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		100	POWTS dispersal component (soil absorption unit or mound)		120

Comment:

Created On: 04-17-2026

Updated On: 05-22-2026

Review Status: APPROVED