Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM671

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MCELROY, JOHN & DEBORAH	Phone #
Mailing Address: 15751 CICERONE PASS	
City: ROSEMOUNT	State: MN Zip Code: 55068

County	Co. Permit #	Notification #	Completed
Adams		10217720201	04-16-2026

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
MARSHALL WELL DRILLING CORP	6946	

Address: 3774 ST RD 13
WISCONSIN DELLS WI 53965-8906

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity
		6.7

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

1. Well Location

Town of STRONGS PRAIRIE

Fire # (if avail.): 1969

Street Address or Road Name and Number: 19TH CROSSING

Subdivision Name	Lot #	Block #
TIMBER SHORES	169	

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.9707 °N -89.944 °W	GPS008

NW SE or Govt Lot #	Section	Township	Range
	6	17 N	5 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9.875	Surface	8
6	8	61

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		S-SAND	Surface	30
	A	Y		A-COARSE Y-SAND & GRAVEL	30	61

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	P.E. STEEL PIPE ASTM A-53 GR.B 18.97 LBS/FT WHEATLAND STEEL	Surface	58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	JOHNSON STAINLESS STEEL 10 SLOT	58	61

7. Grout or Other Sealing Material

Method GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRANULAR BENTONITE	Surface	8	4 S

9. Static Water Level
21 ft. below ground surface

10. Pump Test
Pumping level 24 ft. below surface
Pumping at 20 GP M for 72 Hrs.
Pumping Method ? Test Pump

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
JLJ	7213	04-20-2026
Drill Rig Operator	Lic or Reg #	Date Signed
RGW	7349	04-20-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary	>	125	Building Drain - Sanitary	>	19
			Sewer - Building Sanitary		22

Comment:

Created On: 04-17-2026 Updated On: 05-12-2026 Review Status: APPROVED