

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				ACM671		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner MCELROY, JOHN & DEBORAH						Phone #									
Mailing Address 15751 CICERONE PASS						Town of STRONGS PRAIRIE						Fire # (if avail.) 1969			
City ROSEMOUNT						State MN		Zip Code 55068				Street Address or Road Name and Number 19TH CROSSING			
County Adams		Co. Permit #		Notification # 10217720201		Completed 04-16-2026		Subdivision Name TIMBER SHORES				Lot # 169		Block #	
Well Constructor (Business Name) MARSHALL WELL DRILLING CORP				Lic. # 6946		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.9707 °N -89.944 °W				Method Code GPS008	
Address 3774 ST RD 13 WISCONSIN DELLS WI 53965-8906				Well Plan Approval #				NW SE		Section 6		Township 17 N		Range 5 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #							
Hicap Permanent Well #				Common Well #		Specific Capacity 6.7				2. Well Type New Well				of previous unique well # constructed in	
3. Well serves 1 # of HOME				Hicap Well ? No				Reason for replaced or reconstructed well ?							
Private, potable				Hicap Property ? No											
Heat Exchange ___ # of drillholes				Hicap Potable ? No				Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)			From (ft.)			To (ft.)			Upper Enlarged Drillhole			Lower Open Bedrock			
9.875			Surface			8			No			Rotary - Mud Circulation			
6			8			61			Yes			Rotary - Air			
									No			Rotary - Air & Foam			
									No			Drill-Through Casing Hammer			
									No			Reverse Rotary			
									No			Cable-tool Bit ___ in. dia...			
									No			Dual Rotary			
									No			Temp. Outer Casing ___ in. dia			
									No			Removed? ___ depth ft. (If NO explain on back side)			
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)				To (ft.)			
S				S-SAND				Surface				30			
A Y				A-COARSE Y-SAND & GRAVEL				30				61			
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		11. Well Is					
6		P.E. STEEL PIPE ASTM A-53 GR.B 18.97 LBS/FT WHEATLAND STEEL				Surface		58		18 in. above grade					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Developed ? Yes					
6		JOHNSON STAINLESS STEEL 10 SLOT				58		61		Disinfected ? Yes					
										Capped ? Yes					
7. Grout or Other Sealing Material															
Method GRAVITY															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ? No					
GRANULAR BENTONITE				Surface		8		4 S		Filled & Sealed Well(s) as needed? No					
13. Constructor / Supervisory Driller															
Lic #				Date Signed											
JLJ				7213				04-20-2026							
Drill Rig Operator				Lic or Reg #				Date Signed							
RGW				7349				04-20-2026							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Sewer - Collector - Sanitary	>	125	Building Drain - Sanitary	>	19
			Sewer - Building Sanitary		22

Comment:

Created On: 04-17-2026

Updated On: 05-12-2026

Review Status: APPROVED