Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM687

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RUELLE, JON			Phone #
Mailing Address: 6923 CR Q			
City: MANITOWOC	State: WI	Zip Code: 54220	
County: Manitowoc	Co. Permit #:	Notification #: 10225670601	Completed: 04-17-2026

Well Constructor (Business Name): GROUND SOURCE LLC	Lic. #: 9443	Facility ID # (Public Wells):	
Address: 3671 MONROE ROAD DEPERE WI 54115		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.3	

1. Well Location

Town of KOSSUTH					Fire # (if avail.): 6923
Street Address or Road Name and Number: CR Q					
Subdivision Name:			Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): 44.1824 °N -87.6805 °W					Method Code: GPS008
NW or Govt Lot #:	NW	Section: 30	Township: 20 N		Range: 24 E

2. Well Type Replacement

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: NOT TO CODE

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	73
6	73	160

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Z	C	Z-CLAY & GRAVEL C-CLAYEY	Surface	20
		S		S-SAND	20	35
		C		C-CLAY	35	73
		L		L-LIMESTONE/DOLOMITE	73	160

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW PLN END BLK STEEL WELDED 18.97.280 A53 NUCOR	Surface	73
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

1 ft. above ground surface

10. Pump Test

Pumping level 60 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ? Airlift

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	73	14 S

12. Notified Owner of need to fill & seal ? Yes

Filled & Sealed Well(s) as needed? Yes

PUMP INSTALLER WILL ABANDON

13. Constructor / Supervisory Driller	Lic #	Date Signed
TS	6667	04-20-2026
Drill Rig Operator	Lic or Reg #	Date Signed
CV		04-20-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS holding component (also known as holding tank)		60

Comment:

Created On: 04-17-2026 Updated On: 10-15-2026 Review Status: APPROVED