Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM691

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BANGART, ROBERT	Phone #: (715)393-9883
Mailing Address: 171950 MOLE BROOK RD	
City: RINGLE	State: WI — Zip Code: 54471
County: Marathon	Co. Permit #:
Notification #: 10211777701	Completed: 04-09-2026
Well Constructor (Business Name): DREWS WELL DRILLING INC	Lic. #: 5900
Facility ID # (Public Wells):	
Well Plan Approval #:	
Address: 170001 RINGLE AVE, RINGLE WI 54471	
Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:
Specific Capacity: 0	

1. Well Location

Town of RINGLE

Fire # (if avail.):

Street Address or Road Name and Number: 171950 MOLE BROOK RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.93 °N -89.4003 °W	Method Code: SCR002			
SE SW or Govt Lot #:	Section: 3	Township: 28 N	Range: 9 E	

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?:

Construction Type: Drilled

3. Well serves # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	7
8	7	40
6	40	205

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
Yes	Rotary - Air	Yes
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 8in. dia	
Yes	Removed? 7depth ft. (If NO explain on back side)	

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
B Q	B-BROKEN Q-GRANITE	Surface	7
Q	Q-GRANITE	7	205

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	WHEATLAND A53B 18.97LBS/FT WELDED	Surface	40
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PRESSURE PACKER

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT GROUT	Surface	40	8 S

9. Static Water Level

36.3 ft. below ground surface

10. Pump Test

Pumping level 200 ft. below surface

Pumping at 1.5 GP M for 4 Hrs.

Pumping Method ? Test Pump

11. Well Is

20 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

EXISTING WELL TO BE KEPT FOR FARM USE. WAS ORIGINALLY REPORTED AS STOCK WELL

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJD	5686	04-19-2026
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS treatment component (septic tanks, aerobic treatment units or filters)		175	POWTS dispersal component (soil absorption unit or mound)		190
			Animal Barn or Barn Pen		53

Comment:

Created On: 04-19-2026 Updated On: 05-08-2026 Review Status: APPROVED