Well Construction Report
WISCONSIN UNIQUE WELL NUMBER ACM692

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: RUDEK REV FAMILY TRUST, MARK & RENCIRIS		Phone #	
Mailing Address: 814 HORSE LAKE LANE			
City: DRESSER	State: WI	Zip Code: 54009	
County: Sawyer	Co. Permit #:	Notification #: 10226525901	Completed: 04-20-2026

Well Constructor (Business Name): BUTTERFIELD INC	Lic. #: 7115	Facility ID # (Public Wells):	
Address: 14346 W ST RD 77 HAYWARD WI 54843-9790		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.4	

1. Well Location

Town of HUNTER

Fire # (if avail.): 11151W

Street Address or Road Name and Number: COUNTY HWY B

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
45.98133 °N	-91.24668 °W			GPS008
SE	NW	Section	Township	Range
or Govt Lot # 6	4		40 N	7 W

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ? No

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	81

Upper Enlarged Drillhole		Lower Open Bedrock
Yes	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
No	Cable-tool Bit ____in. dia...	No
No	Dual Rotary	No
No	Temp. Outer Casing ____in. dia	
No	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	M	Y		M-MEDIUM Y-SAND & GRAVEL	Surface	50
	A	Y		A-COARSE Y-SAND & GRAVEL	50	81

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	NAS PVC SDR17 250PSI ASTM F480	Surface	75
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
3	10 CONTINUOUS SLOT STAINLESS STEEL	75	81

7. Grout or Other Sealing Material

Method TREMIE PIPE - PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
TD-16 BENTONITE GROUT	Surface	72	5 S

9. Static Water Level

46 ft. below ground surface

10. Pump Test

Pumping level 53 ft. below surface

Pumping at 10 GP M for 1 Hrs.

Pumping Method ? Test Pump

11. Well Is

14 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No

13. Constructor / Supervisory Driller	Lic #	Date Signed
TAB	6349	04-27-2026
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JSM	7418	04-27-2026

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Lake, Stream, River or Pond (Including Storm Water Detention Basin)	>	200	POWTS dispersal component (soil absorption unit or mound)	=	80
			Septic or Holding, or POWTS Tank	=	50

Comment:

Created On: 04-20-2026 Updated On: 05-22-2026 Review Status: APPROVED